


IntelliSwitch Webserver



The screenshot displays the IntelliSwitch Webserver interface. It features several data fields and control elements:

- DELIVERY** (PSI OXYGEN): 75
- LEFT** (PSI OXYGEN): 355
- RIGHT** (PSI OXYGEN): 2185
- SWITCHOVER PRESSURE**: 135
- HYSTERESIS**: 10
- LOOK BACK**: 30
- SWITCH BACK**: 10
- VERSION**: 3.02
- SYSTEM I.D.**: 1

Status indicators for 'READY', 'REPLACE', and 'IN-USE' are shown for both left and right sides. 'CYLINDER SELECTION' options include 230 PSI, 350 PSI, 500 PSI, and H. P. The interface also includes a 'CONCOA' logo, 'R1.00', and buttons for 'REFRESH', 'EDIT', 'ALARM CLEAR', 'EVENT LOG', 'CLEAR LOG', and 'PRINT LOG'.

CONFIGURATION INSTRUCTIONS

The IntelliSwitch Web Server is configured with the following factory settings

NETWORK

IP Address: 192.168.0.83

Subnet Mask: 255.255.255.0

Default Gateway: 192.168.0.100

DHCP not enabled. DNS not set. Contact IT administrator for configuration assistance.

SECURITY

To update the network settings navigate to <http://192.168.0.83/config/config.html> and supply the following credentials:

Username: admin

Password: PASS

Concoa strongly suggests that this device be placed behind a firewall. It is not suitable for public internet access.

Warranty Information

This equipment is sold by CONTROLS CORPORATION OF AMERICA under the warranties set forth in the following paragraphs. Such warranties are extended only with respect to the purchase of this equipment directly from CONTROLS CORPORATION OF AMERICA or its Authorized Distributors as new merchandise and are extended to the first Buyer thereof other than for the purpose of resale.

For a period of one (1) year from the date of original delivery (90 days in corrosive service) to Buyer or to Buyer's order, this equipment is warranted to be free from functional defects in materials and workmanship and to conform to the description of this equipment contained in this manual and any accompanying labels and/or inserts, provided that the same is properly operated under conditions of normal use and that regular periodic maintenance and service is performed or replacements made in accordance with the instructions provided. The foregoing warranties shall not apply if the equipment has been repaired: other than by CONTROLS CORPORATION OF AMERICA or a designated service facility in accordance with written instructions provided by CONTROLS CORPORATION OF AMERICA; or altered by anyone other than CONTROLS CORPORATION OF AMERICA; or if the equipment has been operated under improper conditions or outside published specifications; or if the equipment has been damaged or does not function due to improper installation, improper supply of required utilities, accident, abuse, misuse, natural disaster, insufficient or excessive electrical supply, abnormal mechanical or environmental conditions, or debris or particles in the gas or liquid source of supply.

CONTROLS CORPORATION OF AMERICA's sole and exclusive obligation and Buyer's sole and exclusive remedy under the above warranties is limited to repairing using new or reconditioned parts or replacing, free of charge except for labor if permanently installed for the continuous supply of gas by other than a technician certified by CONTROLS CORPORATION OF AMERICA specifically to do so, at CONTROLS CORPORATION OF AMERICA's option, the equipment or part, which is either (1) reported to its Authorized Distributor from whom purchased, and which if so advised, is returned with a statement of the observed deficiency, and proof of purchase of equipment or part not later than seven (7) days after the expiration date of the applicable warranty, to the nearest designated service facility during normal business hours, transportation charges prepaid, and which upon examination, is found not to comply with the above warranties with return trip transportation charges for the equipment or part paid by Buyer or (2) in the case of designated equipment permanently installed for the continuous supply of gas, reported to an Authorized Service Center with proof of initial installation no later than seven (7) days after the expiration date of the applicable warranty, and which is evaluated for compliance with the above warranties by technician certified by CONTROLS CORPORATION OF AMERICA, and which is determined by CONTROLS CORPORATION OF AMERICA based on said evaluation to be non-compliant.

CONTROLS CORPORATION OF AMERICA SHALL NOT BE OTHERWISE LIABLE FOR ANY DAMAGES INCLUDING BUT NOT LIMITED TO: INCIDENTAL DAMAGES, CONSEQUENTIAL DAMAGES, OR SPECIAL DAMAGES, WHETHER SUCH DAMAGES RESULT FROM NEGLIGENCE, BREACH OF WARRANTY OR OTHERWISE.

THERE ARE NO EXPRESS OR IMPLIED WARRANTIES WHICH EXTEND BEYOND THE WARRANTIES HEREINABOVE SET FORTH. CONTROLS CORPORATION OF AMERICA MAKES NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE WITH RESPECT TO THE EQUIPMENT OR PARTS THEREOF.